

## Bid Document

Bid Details	
<b>Bid End Date/Time</b>	17-01-2022 13:00:00
<b>Bid Opening Date/Time</b>	17-01-2022 13:30:00
<b>Bid Life Cycle (From Publish Date)</b>	90 (Days)
<b>Bid Offer Validity (From End Date)</b>	45 (Days)
<b>Ministry/State Name</b>	Pmo
<b>Department Name</b>	Department Of Atomic Energy
<b>Organisation Name</b>	Iter India Ipr
<b>Office Name</b>	literindia Ipr Blocka Sangath Skyz Bhatmote
<b>Total Quantity</b>	28
<b>Item Category</b>	Miniature Circuit Breakers-IS 60898-1:2002 (Q3)
<b>MSE Exemption for Years of Experience and Turnover</b>	No
<b>Startup Exemption for Years of Experience and Turnover</b>	No
<b>Document required from seller</b>	Additional Doc 1 (Requested in ATC), Additional Doc 2 (Requested in ATC) *In case any bidder is seeking exemption from Experience / Turnover Criteria, the supporting documents to prove his eligibility for exemption must be uploaded for evaluation by the buyer
<b>Bid to RA enabled</b>	No
<b>Primary product category</b>	Miniature Circuit Breakers-IS 60898-1:2002
<b>Time allowed for Technical Clarifications during technical evaluation</b>	5 Days
<b>Evaluation Method</b>	Total value wise evaluation

### EMD Detail

Required	No
----------	----

### ePBG Detail

Required	No
----------	----

### Splitting

Bid splitting not applied.

### MII Purchase Preference

MII Purchase Preference	No
-------------------------	----

### MSE Purchase Preference

MSE Purchase Preference	Yes
-------------------------	-----

1. Purchase preference to Micro and Small Enterprises (MSEs): Purchase preference will be given to MSEs as defined in Public Procurement Policy for Micro and Small Enterprises (MSEs) Order, 2012 dated 23.03.2012 issued by Ministry of Micro, Small and Medium Enterprises and its subsequent Orders/Notifications issued by concerned Ministry. If the bidder wants to avail the Purchase preference, the bidder must be the manufacturer of the offered product in case of bid for supply of goods. Traders are excluded from the purview of Public Procurement Policy for Micro and Small Enterprises. In respect of bid for Services, the bidder must be the Service provider of the offered Service. Relevant documentary evidence in this regard shall be uploaded along with the bid in respect of the offered product or service. If L-1 is not an MSE and MSE Seller (s) has/have quoted price within L-1+ 15% (Selected by Buyer) of margin of purchase preference /price band defined in relevant policy, such Seller shall be given opportunity to match L-1 price and contract will be awarded for 25%(selected by Buyer) percentage of total QUANTITY.

2. Estimated Bid Value indicated above is being declared solely for the purpose of guidance on EMD amount and for determining the Eligibility Criteria related to Turn Over, Past Performance and Project / Past Experience etc. This has no relevance or bearing on the price to be quoted by the bidders and is also not going to have any impact on bid participation. Also this is not going to be used as a criteria in determining reasonableness of quoted prices which would be determined by the buyer based on its own assessment of reasonableness and based on competitive prices received in Bid / RA process.

### Miniature Circuit Breakers-IS 60898-1:2002 ( 1 pieces )

Brand Type	Registered Brand
------------	------------------

### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	63 A
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	415 VOLT
	<b>No of poles/Protected poles(PP)</b>	4 pole with 3PP

**Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 1 pieces )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short Circuit capacity (Ampere)	7000A/10000A/25000A
Item Details	Miniature Current Circuit Breaker, 4Poles with 4PP, Current rated (Ampere) 125 A, Rated Short Circuit Capacity (Ampere) 7000A/10000A/25000A, Instantaneous Tripping Range "C", Rated Voltage 415 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

**Consignees/Reporting Officer and Quantity**

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005,ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	1	30

**Miniature Circuit Breakers-IS 60898-1:2002 ( 2 )**

Brand Type	Registered Brand
------------	------------------

**Technical Specifications**

\* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	63 A
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	240 VOLT, 415 VOLT
	<b>No of poles/Protected poles(PP)</b>	2 pole with 2 PP

**Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 2 )**

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short circuit capacity (Ampere)	7000A/10000A/25000A
Item Details	Miniature Current Circuit Breaker, 2Poles with 2PP, Current rated (Ampere) 125 A, Rated Short Circuit Capacity (Ampere) 7000A/10000A/25000A, Instantaneous Tripping Range "C", Rated Voltage 415/250 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005,ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	2	30

#### Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Brand Type	Registered Brand
------------	------------------

#### Technical Specifications

[\\* As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	1.0 a
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	240 VOLT, 415 VOLT
	<b>No of poles/Protected poles(PP)</b>	2 pole with 2 PP

#### Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short Circuit Capacity	6000A / 10000A

Specification Parameter Name	Bid Requirement (Allowed Values)
Item Details	Miniature Current Circuit Breaker, 2Poles with 2PP, Current rated (Ampere) 1A, Rated Short Circuit Capacity (Ampere) 6000A/10000A, Instantaneous Tripping Range "C", Rated Voltage 250 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005,ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	5	30

#### Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Brand Type	Registered Brand
------------	------------------

#### Technical Specifications

\* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	2.0 a
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	240 VOLT
	<b>No of poles/Protected poles(PP)</b>	2 pole with 2 PP

#### Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short Circuit capacity (Ampere)	6000A / 10000A

Specification Parameter Name	Bid Requirement (Allowed Values)
Item Details	Miniature Current Circuit Breaker, 2Poles with 2PP, Current rated (Ampere) 2A, Rated Short Circuit Capacity (Ampere) 6000A/10000A, Instantaneous Tripping Range "C", Rated Voltage 250 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005, ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	5	30

#### Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Brand Type	Registered Brand
------------	------------------

#### Technical Specifications

\* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	40 A
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	415 VOLT
	<b>No of poles/Protected poles(PP)</b>	3pole with 3PP

#### Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short Circuit capacity (Ampere)	7000A /10000A /25000A

Specification Parameter Name	Bid Requirement (Allowed Values)
Item Details	Miniature Current Circuit Breaker, 3Poles with 3PP, Current rated (Ampere) 40 A, Rated Short Circuit Capacity (Ampere) 7000A/10000A/25000A, Instantaneous Tripping Range "C", Rated Voltage 415 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005,ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	5	30

#### Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Brand Type	Registered Brand
------------	------------------

#### Technical Specifications

\* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	40 A
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	415 VOLT
	<b>No of poles/Protected poles(PP)</b>	4 pole with 3PP

#### Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short Circuit capacity (Ampere)	10000A /25000A

Specification Parameter Name	Bid Requirement (Allowed Values)
Item Details	Miniature Current Circuit Breaker, 4Poles with 4PP, Current rated (Ampere) 40 A, Rated Short Circuit Capacity (Ampere) 10000A/25000A, Instantaneous Tripping Range "C", Rated Voltage 415 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005, ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	5	30

#### Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Brand Type	Registered Brand
------------	------------------

#### Technical Specifications

\* [As per GeM Category Specification](#)

Specification	Specification Name	Bid Requirement (Allowed Values)
CONSTRUCTIONAL	Steel sheet enclosure for MCB of 1.2 mm thickness duly pretreated stove enamelled/powder coated	Without
GENERIC	<b>Rated Current (Ampere)</b>	63 A
	<b>Instantaneous Tripping Range</b>	C
	<b>Rated Voltage (Volt)</b>	415 VOLT
	<b>No of poles/Protected poles(PP)</b>	4 pole with 3PP

#### Additional Specification Parameters - Miniature Circuit Breakers-IS 60898-1:2002 ( 5 pieces )

Specification Parameter Name	Bid Requirement (Allowed Values)
Rated Short Circuit capacity (Ampere)	10000A /25000A



Specification Parameter Name	Bid Requirement (Allowed Values)
Item Details	Miniature Current Circuit Breaker, 4Poles with 4PP, Current rated (Ampere) 63 A, Rated Short Circuit Capacity (Ampere) 10000A/25000A, Instantaneous Tripping Range "C", Rated Voltage 415 VOLT

\* Bidders offering must also comply with the additional specification parameters mentioned above.

#### Consignees/Reporting Officer and Quantity

S.No.	Consignee/Reporting Officer	Address	Quantity	Delivery Days
1	Mayurkumar Navinchandra Patel	380005,ITER-INDIA, IPR, BLOCK-A, SANGATH SKYZ, BHAT-MOTERA ROAD, KOTESHWAR, AHMEDABAD-380005, GUJARAT, INDIA	5	30

### Buyer Added Bid Specific Terms and Conditions

#### 1. Generic

Actual delivery (and Installation & Commissioning (if covered in scope of supply)) is to be done at following address ECRH Lab, ITER-India Lab Building, Institute For Plasma Research Near Mother Dairy, Bhat Village, Gandhinagar-382428, Gujarat, India.

#### 2. Generic

Supplier shall ensure that the Invoice is raised in the name of Consignee with GSTIN of Consignee only.

#### 3. Generic

The buyer organization is an institution eligible for concessional rates of GST as notified by the Government of India. The goods for which bids have been invited fall under classification of GST concession and the conditions for eligibility of concession are met by the institution. A certificate to this effect will be issued by Buyer to the Seller after award of the Contract. Sellers are requested to submit their bids after accounting for the Concessional rate of GST.

Applicable Concessional rate of GST : 5%

Notification No.and date : 47/2017 - Integrated Tax (Rate) , 45/2017-Central Tax (Rate) dated 14/11/2017 and 45/2017 - State Tax (Rate) dated dated 15/11/2017

#### 4. Generic

While generating invoice in GeM portal, the seller must upload scanned copy of GST invoice and the screenshot of GST portal confirming payment of GST.

#### 5. Scope of Supply

Scope of supply (Bid price to include all cost components) : Only supply of Goods

#### 6. Buyer Added Bid Specific ATC

Buyer Added text based ATC clauses

**1. Warranty:** 12 Months from the date of final acceptance of ordered items by Purchaser against all sorts of manufacturing defects, faulty material and poor workmanship.

## **Disclaimer**

The additional terms and conditions have been incorporated by the Buyer after approval of the Competent Authority in Buyer Organization. Buyer organization is solely responsible for the impact of these clauses on the bidding process, its outcome and consequences thereof including any eccentricity / restriction arising in the bidding process due to these ATCs and due to modification of technical specification and / or terms and conditions governing the bid. Any clause incorporated by the Buyer such as demanding Tender Sample, incorporating any clause against the MSME policy and Preference to make in India Policy, mandating any Brand names or Foreign Certification, changing the default time period for Acceptance of material or payment timeline governed by OM of Department of Expenditure shall be null and void and would not be considered part of bid. Further any reference of conditions published on any external site or reference to external documents / clauses shall also be null and void. If any seller has any objection / grievance against these additional clauses or otherwise on any aspect of this bid, they can raise their representation against the same by using the Representation window provided in the bid details field in Seller dashboard after logging in as a seller within 4 days of bid publication on GeM. Buyer is duty bound to reply to all such representations and would not be allowed to open bids if he fails to reply to such representations.

[This Bid is also governed by the General Terms and Conditions](#)

In terms of GeM GTC clause 26 regarding Restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.

**---Thank You---**